



COUNTY SANITATION DISTRICTS OF LOS ANGELES COUNTY

1955 Workman Mill Road, Whittier, CA 90601-1400
Mailing Address: P.O. Box 4998, Whittier, CA 90607-4998
Telephone: (562) 699-7411, FAX: (562) 699-5422
www.lacsd.org

STEPHEN R. MAGUIN
Chief Engineer and General Manager

April 8, 2008

Mr. Dan Jimenez
Santa Clarita Water Conditioning
28150 Avenue Crocker, Suite 201
Valencia, CA 91355

Dear Mr. Jimenez:

**Installation of the Hydromagnetic Activated Carbon and Scale Prevention Systems
in the Santa Clarita Valley**

Per your request, the Santa Clarita Valley Sanitation District (Sanitation District) has reviewed the wastes generated by the use of the Hydromagnetic Activated Carbon and Scale Prevention Systems. Since the systems do not generate a high-salt waste stream, they are not subject to the ordinance passed by the Sanitation District that prohibits the installation of self-regenerating water softeners. These systems may continue to be installed in the Santa Clarita Valley area.

Please note that this letter does not constitute an endorsement of any particular product, nor does it provide any assurances regarding the effectiveness of any potable water treatment system. If you have any questions about this letter or require additional information, please contact Ms. Preeti Ghuman of the Sanitation District's Industrial Waste Section by phone at (562) 699-7411, extension 2904 or by e-mail at pghuman@lacsd.org.

Very truly yours,

Stephen R. Maguin

Paul C. Martyn
Head, Industrial Waste Section

PCM:PG:dfd
Docs: 1005889